

泳池水质月度检测报告

Monthly Report of Swimming Pool Water Quality Testing

样品名称 Sample name	游泳池水 Swimming pool water		采样日期 Sampling date	1/6/23	报告日期 Date of report	1/13/23
检测项目 Test items	单位 Unit	深水区 Deep water area	浅水区 Shallow water area	小泳池 Small swimming pool	标准值 Standard value	判定结果 Judgment result
PH值 PH value	无量纲 Dimensionless	7.17	7.16	7.20	7.0~7.8	合格 Up to the standard
浑浊度 Turbidity	NTU	0.58	0.60	0.55	≤1	合格 Up to the standard
游离余氯 Free residual chlorine	mg/L	0.40	0.42	0.47	0.3~1.0	合格 Up to the standard
化合性余氯 Combined residual chlorine	mg/L	0.23	0.27	0.25	≤0.4	合格 Up to the standard
尿素 Urea	mg/L	2.06	2.13	1.94	≤3.5	合格 Up to the standard
细菌总数 Total bacteria count	CFU/mL	145	120	130	≤200	合格 Up to the standard
大肠菌群 Coliform bacteria	MPN/100mL	未检出 Not detectable	未检出 Not detectable	未检出 Not detectable	不得检出 Not detectable	合格 Up to the standard
氧化还原电位 Oxidation-reduction potential	mV	748	765	831	≥650	合格 Up to the standard
氰尿酸 Cyanuric acid	mg/L	23	27	24	≤50	合格 Up to the standard
结论依据 Basis of conclusion	GB 37488-2019《公共场所卫生指标及限值要求》 GB 37488-2019 Hygienic Indicators and Limits for Public Places					
检测结论 Test conclusion	经检测，所测结果符合GB 37488-2019《公共场所卫生指标及限值要求》 After testing, the tested results meet GB 37488-2019 Hygienic Indicators and Limits for Public Places					
检测机构 Testing organization	江苏省百斯特检测技术有限公司 Jiangsu Best Test Technology Co., Ltd.					